

## **AMENDMENT # 1 – QUESTIONS AND ANSWERS RELATED TO THIS PROJECT**

### **ON-CALL SERVICES FOR TRENCHLESS PIPELINE REHABILITATION TOWN OF HUDSON, NEW HAMPSHIRE**

In the interest of fairness and sound business practice, the Town will provide answers for questions we have received for this project. Deadline for all questions was May 20, 2022. It shall be the responsibility of the Contractor to be aware of this amendment and providing this document with the bid documents.

Question 1: Are the sectional repairs a dig item or CIPP item?

Answer 1: Contractor shall only be responsible for CIPP item. DPW will make the determination of what's required and if dig repair is required it will coordinate the excavation with the Contractor. The Contractor shall be responsible for providing a bid for all the items, on the bid schedule, including point sectional repairs.

Question 2: Will Zia/VeriCure be required on all pipe sizes or just those over 18"?.?

Answer 2: This will be determined by Town staff based on the scenarios and options available. Contractor shall able to provide all options.

Question 3:What are the Work Hours?

Answer 3: 7 AM- 7 PM , Monday – Saturday

Question 4: Who pays for Traffic Control?

Answer 4: All contractors will provide a separate cost item for flaggers ( \$/ hour /flagger) . The Town reserves the right to provide its own traffic control

Question 5:Is there a Cost of water usage?

Answer 5: The Town will provide the water access, at no cost, weather pending. The contractor is responsible to provide a suitable backflow device or air gap.

Question 6: Are most of the pipes ACP? VCP? RCP?

Answer 6: Town of Hudson has a mix of pipe inventory including ACP, VCP, RCP, CP, and PVC.

Question 7: Will there be a separate bid item for cutting SC's?

Answer 7: This could be an add on item added to the bid schedule.

Question 8: 8. Will the scope be mostly street work or easement work?

Answer 8: Most of the proposed work is street work but easement work could also be involved

Signed: \_\_\_\_\_

**I DO** understand the above and agree to meet specifications

Signed: \_\_\_\_\_

**I DO NOT** meet specifications as listed in this amendment

Failure to submit this amendment form with your RFP response may result in your Proposal being rejected as unresponsive.

Company: \_\_\_\_\_

Signed by: \_\_\_\_\_

Printed or typed name: \_\_\_\_\_

Address: \_\_\_\_\_

Telephone number: \_\_\_\_\_ fax number: \_\_\_\_\_

Toll free number: \_\_\_\_\_ e-mail: \_\_\_\_\_

Cell phone number: \_\_\_\_\_

Primary point of contact: \_\_\_\_\_

Payment terms and conditions: \_\_\_\_\_

Please fill out, sign and return to:

Town of Hudson  
Town Engineer  
Mr. Elvis Dhima, P.E.,  
12 School Street, Hudson, NH 03051  
603-886-6008; 603-594-1142 (Fax)  
edhima@hudsonnh.gov

**Due Date/Time: MAY 20, 2022 Not Later Than 10:00 AM**