

## **AMENDMENT # 1 – QUESTIONS AND ANSWERS RELATED TO THIS PROJECT**

### **LINING SERVICES FOR FLAGSTONE DRAINAGE MAIN TOWN OF HUDSON, NEW HAMPSHIRE**

In the interest of fairness and sound business practice, the Town will provide answers for questions we have received for this project. Deadline for all questions was November 26, 2021. It shall be the responsibility of the Contractor to be aware of this amendment and providing this document with the bid documents.

Question 1: Are there more detailed plans available?

Answer 1: Not at this time

Question 2: The plans provided a not very clear, and we would like to see more of the upstream and downstream systems for bypass purposes as well.

Answer 2: There are five available video segments from July 2021 on the Town RFP website. The contractor shall be responsible for interpretation, determining the best and most feasible option to address existing obstacles in the pipe

Question 3: Are there video inspections available?

Answer 3: Yes, five videos segments are available on the Town website RFP webpage.

Question 4: What is the flow rate of the 30” pipeline?

Answer 4: The flow varies along the length of the pipe. Video footage is available for the contractor to determine that flow and the necessary bypass required for this project. Contractors are allowed to conduct site investigation, if they wish.

Question 5: Does the Owner anticipate trenching for bypass crossings, or are road ramps acceptable?

Answer 5: On road ramps are acceptable.

Question 6: Are there any laterals present in the 30” pipeline?

Answer 5: Yes, please refer to the footage available on Town website. Contractor shall be responsible for all necessary adjustment to allow a continues UV liner through the main drainage line. Contractor shall be responsible for any removal of debris or obstacles in the way.

Question 7: Who will be responsible for notifications?

Answer 7: The contractor shall be responsible for the notifications, if necessary. The Town will assist with providing addresses for adjacent properties to this project.

Question 8: Will work during the weekends be allowed?

Answer 8: Yes, with Public Works and Engineering Departments written approval.

Question 9: Who is responsible for traffic detail?

Answer 9: The contractor shall be responsible for the traffic detail or detour, if necessary. The Town will assist with traffic detail feedback.

Question 10: What is the pipe size and length?

Answer 10: Our records indicate a 30 inch pipe. The length of the job is not to exceed 1,600 linear feet.  
The contractor shall be responsible for confirming and verifying diameter and depth.

Signed: \_\_\_\_\_

**I DO** understand the above and agree to meet specifications

Signed: \_\_\_\_\_

**I DO NOT** meet specifications as listed in this amendment

Failure to submit this amendment form with your RFP response may result in your Proposal being rejected as unresponsive.

Company: \_\_\_\_\_

Signed by: \_\_\_\_\_

Printed or typed name: \_\_\_\_\_

Address: \_\_\_\_\_

Telephone number: \_\_\_\_\_ fax number: \_\_\_\_\_

Toll free number: \_\_\_\_\_ e-mail: \_\_\_\_\_

Cell phone number: \_\_\_\_\_

Primary point of contact: \_\_\_\_\_

Payment terms and conditions: \_\_\_\_\_

Please fill out, sign and return to:

Town of Hudson  
Town Engineer  
Mr. Elvis Dhima, P.E.,  
12 School Street, Hudson, NH 03051  
603-886-6008; 603-594-1142 (Fax)  
edhima@hudsonnh.gov

**Due Date/Time: DECEMBER 3, 2021, Not Later Than 10:00 AM**