



# TOWN OF HUDSON

## FIRE DEPARTMENT - INSPECTIONAL SERVICES DIVISION

12 School Street • Hudson, New Hampshire 03051 • Tel: 603-886-6005 • Fax: 603-594-1142

### SOLID FUEL PERMIT APPLICATION

Installation Address: _____		<b>Office Use:</b>
Business Name: _____ Unit: _____		Permit #: _____
Type of Occupancy: Residential <input type="checkbox"/> Commercial/Industrial <input type="checkbox"/>		Map: _____
Estimated Cost: _____ Permit Fee: _____		Lot: _____
		Zone: _____
Make : _____ Model: _____ Serial: _____		
Fuel: Wood <input type="checkbox"/> Pellet <input type="checkbox"/> Coal <input type="checkbox"/>		
Owner: _____	Contractor: _____	
Mailing Address: _____	Mailing Address: _____	
Daytime Phone #: _____	Daytime Phone #: _____	
Cell Phone #: _____	Cell Phone #: _____	
Email: _____	Email: _____	
My signature below indicates the above mentioned unit will be installed according to the latest rules and regulations of the unit manufacturer, NFPA 211 and the Hudson Inspectional Services Division.		
_____ Signature of Installer	_____ Date	
_____ Signature of ISD Authorized Representative	_____ Date	

### SOLID FUEL BURNING APPLIANCE REQUIREMENTS

1. Unit shall be installed to manufacturer's installation guide requirements.
2. Manufacturer's installation guide must be available during inspection.
3. If for any reason the guide is not available, the following NFPA-211 requirements shall apply:
  - a. 36 inches from combustibles
  - b. 18 inch floor protection in front of and to the sides
  - c. 18 inches from flu pipe to combustibles
4. Clearance reductions shall comply with Table 12.6.2.1 of the current edition of NFPA 211.
5. Appliances shall not be installed in any location where gasoline or any other flammable vapors or gases are present.
6. Appliances shall not be installed in any garage.